

COVINGTON ELECTRIC COOPERATIVE
UNDERGROUND TYPE INSTALLATION
METER SOCKET, SINGLE - PHASE

NOTES:

1. COOPERATIVE WILL DETERMINE POINT OF ATTACHMENT TO BUILDING.
2. MINIMUM AMPACITY 200 AMPS.
3. LEAD PLUGS SHALL BE USED ON MASONRY TYPE CONSTRUCTION TO SECURE CONDUIT STRAPS.
4. THIS DIAGRAM IS INTENDED FOR USE AS A GUIDE. ALL CONSTRUCTION SHALL CONFORM TO THE CURRENT EDITION OF THE NATIONAL ELECTRICAL CODE, EXCEPT THAT LOCAL CODES AND REGULATIONS HAVING JURISDICTION SHALL TAKE PRECEDENCE.
5. A MAXIMUM OF (6) DISCONNECTS SHALL BE PERMITTED IN A DISTRIBUTION PANEL WITHOUT A MAIN DISCONNECT TO DISCONNECT ELECTRICITY TO ALL DISTRIBUTION CIRCUITS.
6. POWER PANELS ARE ACCEPTABLE
7. FOR SERVICES LARGER THAN 200A, CONTACT THE COOPERATIVE FOR WIRING SPECIFICATIONS.

