

COVINGTON ELECTRIC COOPERATIVE

METER POLE INSTALLATION

UNDERGROUND SERVICE

SINGLE - PHASE

NOTES:

1. MINIMUM AMPACITY 200 AMPS.
THIS MAY BE REDUCED FOR TEMPORARY SERVICE ONLY WITH APPROVAL FROM THE COOPERATIVE'S ENGINEERING DEPT. PRIOR TO INSTALLATION.
2. SINGLE - PHASE SERVICE ONLY.
3. THIS DIAGRAM IS INTENDED FOR USE AS A GUIDE.
ALL CONSTRUCTION SHALL CONFORM TO THE CURRENT EDITION OF THE NATIONAL ELECTRICAL CODE, EXCEPT THAT LOCAL CODES AND REGULATIONS HAVING JURISDICTION SHALL TAKE PRECEDENCE.
4. LEAD PLUGS SHALL BE USED ON MASONRY TYPE CONSTRUCTION TO SECURE CONDUIT STRAPS.
5. A MAXIMUM OF (6) DISCONNECTS SHALL BE PERMITTED IN A DISTRIBUTION PANEL WITHOUT A MAIN DISCONNECT TO DISCONNECT ELECTRICITY TO ALL DISTRIBUTION CIRCUITS.
6. FOR SERVICES LARGER THAN 200A, CONTACT THE COOPERATIVE FOR WIRING SPECIFICATIONS.

